



# Output 1 – Electric Strike Lock Fail Secure (12V DC ONLY)

Output 1: Lock requires power to unlock. Power applied when access is granted.

This drawing is for reference only. All field connections should be engineered and performed in accordance.			
DRAWN BY: Chris Pryor <a href="mailto:support@lobibox.com">support@lobibox.com</a>	SIZE B	DWG Title Electric Strike Lock – Fail Secure	REV A
ISSUED: 5/13/2021	LobiBox – 5090 N 40 <sup>th</sup> St., Phoenix, AZ 85018	SCALE Not to scale	SHEET 1 OF 1